ORBIT 60 SERIES Condition Monitoring Module Datasheet

Bently Nevada Machinery Condition Monitoring

145M9028 Rev. A



Description

The Condition Monitoring Module (CMM) listens to all information within the system, including all measurements, waveforms, digital transducer signals, system controls, status information, system configuration information, process data from external systems, and alarm and events logs. It only listens, with no capability to write, allowing interface to System I over the business networks, with no risk to the protection system.

Each module occupies two slots within the system. Placing multiple CMM modules allows the connection of two independent System 1 clients to the Orbit 60 System. Data is transferred to System 1 continuously, but in the event the connection is lost, non-volatile storage buffers historical data until the information is off-loaded to the host software. System 1 can configure the CMM module to extract additional measurements and waveforms from system sensor data. Without System 1, the customer can use the CMM module to collect data to diagnose machinery issues when an alarm event occurs in the hardware.

Each module has two independently configurable RJ-45 Ethernet ports. OK LEDs indicate proper operation and LINK LEDs show good communication to the system.





Condition Monitoring Module

Condition Monitoring Module (CMM)			
Power Consumption			
Maximum	14.2 W		
Typical	10.5 W		
Data Communications			
2 Ethernet ports - utility or rear side	Independent Ethernet ports 1000/100/10 Base-T Auto- negotiation		
Connector	RJ-45		
Cable Length	100 meters (328 feet) max		
LEDs			
Module OK LED	Indicates when the module is functioning properly		
LINK LED	indicates when the module is communicating to the rest of the system		
Physical			
Required Rack Space	2 Slots		

Environmental Limits 3U Chassis: Chassis -30°C to +70°C Operating A (-22°F to 158°F) Temperature Range 6U Chassis: -30°C to +65°C (indoor use (-22°F to 149°F) only) -30°C to +70°C Module (-22°F to 158°F) Temperature Rating -You must still meet Certification ۱ the Chassis Operating Temperature Range defined above. Storage -40°C to +85°C (-40° F to 185° F) Temperature Range Relative 0% to 95% rH non-condensing Humidity operating and storage Without Isolators: Vibration 0 g to 0.35 g @ 57-500 Hz With Isolators: 0 g to 5 g @ 57-500 Hz. Shock 2" Incline Drop < 2000 m (6,562 ft) Altitude Higher altitudes are possible but are site specific applications. Contact Bently Nevada



support if you require higher altitudes.

Pollution Degree 2

Category II

145M9028 Rev. A

Pollution

Installation

Category

Degree



<u>/</u>

Verify that temperature ratings on the wiring cables match the operating temperature range.

CAUTION

LOCATION TEMPERATURE AND HUMIDITY



If you install the hardware in a location where temperatures may exceed 40° C (104° F) or in excessive humidity, you should consider supplying environmental controls. High temperatures will reduce the operational life of the system.



Compliance and Certifications

FCC

This device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions:

- This device may not cause harmful interference.
- This device must accept any interference received, including interference that may cause undesired operation.

EMC

European Community Directive:

EMC Directive 2014/30/EU

Standards:

EN 61000-6-2; Immunity for Industrial Environments EN 61000-6-4; Emissions for Industrial Environments

Electrical Safety

European Community Directive:

LV Directive 2014/35/EU

Standards:

EN 61010-1; EN 61010-2-201;

RoHS

European Community Directive:

RoHS Directive 2011/65/EU

Cyber Security

Designed to meet IEC 62443-4-2

*Maritime

ABS Rules for Condition of Classification, Part 1

- Steel Vessels Rules
- Offshore Units and Structures

* Approvals pending

Functional Safety

This component is non-interfering with the safety system. The system SIL 2 certification does not require this component be SIL certified.

Hazardous Area Approvals



For the detailed listing of country and product-specific approvals, refer to the *Approvals Quick Reference Guide* (108M1756).

For additional technical documentation, please log in to <u>bntechsupport.com</u> and access the Bently Nevada Media Library.

cNRTLus

Class I, Zone 2: AEx/Ex ec nC IIC T4 Gc; Class I, Zone 2: AEx/Ex nA nC IIC T4 Gc; Class I, Division 2, Groups A, B, C, D T4; Class I, Division 2, Groups A, B, C, D T4 (N.I.);

T4 @ Ta = -30° C to $+70^{\circ}$ C (-22° F to $+158^{\circ}$ F)

ATEX/IECEx

Ex ec nC IIC T4 Gc Ex nA nC IIC T4 Gc

T4 @ Ta = -30° C to $+70^{\circ}$ C (-22° F to $+158^{\circ}$ F)



Ordering Information



For the detailed listing of country and product-specific approvals, refer to the *Approvals Quick Reference Guide* (108M1756).

For additional technical documentation, please log in to <u>bntechsupport.com</u> and access the Bently Nevada Media Library.

Condition Monitoring Module

Ordering Option	Description
60R/CMM01-AAA-E	3

AAA - Hazardous Area Certifications

00	No Hazardous Area	
01	CSA/NRTL/C (Class I, Div 2)	
02	Multi (CSA, ATEX, IECEx)	
XXX	Country Specific Approvals	
B – SIL Level		
0	No SIL	



Copyright 2023 Baker Hughes Company. All rights reserved.



Bently Nevada and Orbit Logo are registered trademarks of Bently Nevada, a Baker Hughes business, in the United States and other countries. The Baker Hughes logo is a trademark of Baker Hughes Company. All other product and company names are trademarks of their respective holders. Use of the trademarks does not imply any affiliation with or endorsement by the respective holders.

Baker Hughes provides this information on an "as is" basis for general information purposes. Baker Hughes does not make any representation as to the accuracy or completeness of the information and makes no warranties of any kind, specific, implied or oral, to the fullest extent permissible by law, including those of merchantability and fitness for a particular purpose or use. Baker Hughes hereby disclaims any and all liability for any direct, indirect, consequential or special damages, claims for lost profits, or third party claims arising from the use of the information, whether a claim is asserted in contract, tort, or otherwise. Baker Hughes reserves the right to make changes in specifications and features shown herein, or discontinue the product described at any time without notice or obligation. Contact your Baker Hughes representative for the most current information.

The information contained in this document is the property of Baker Hughes and its affiliates; and is subject to change without prior notice. It is being supplied as a service to our customers and may not be altered or its content repackaged without the express written consent of Baker Hughes. This product or associated products may be covered by one or more patents. See Bently.com/legal.

1631 Bently Parkway South, Minden, Nevada USA 89423 Phone: 1.775.782.3611 (US) or Bently.com/support Bently.com

